TÜVNORD

Certificate

of Conformity

This certifies that below described product(s) of the company:

WUXI ZEVO NEW ENERGY TECH CO., LTD
Room 801, (CIC Park), No. 22 Zhihui Road
Huishan District Wuxi (214100)
P.R. China

comply to the essential requirements of the following standards

Description of product(s) (details see Annex):	**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Certification program:	P12-VA-01 Rev. 17 / 09.20
Certification fundamental(s):	EN IEC 61730-1:2018, EN IEC 61730-2:2018

This certificate of conformity is based on the evaluation of samples of the product. It does not imply an assessment of the production and it does not permit the use of a mark of conformity or of a safety mark of TÜV NORD CERT GmbH.
The company may use this certificate as a basis of compliance with 2014/35/EU - low voltage directive, together with EU declaration of conformity (DoC) issued by the company. The CE marking may be affixed on the product if all relevant and effective directives and requirements are complied with, under full responsibility of the company.

Registration no.:	44 799 26 406749 - 068
Report no.:	492014228.001
File no.:	PVP07140/25P-01

Essen, 2026-02-12
Certification Body - Consumer Products

TÜV NORD CERT GmbH
Am TÜV 1, 45307 Essen, Germany
tuev-nord-cert.de | prodcert@tuev-nord.de

Please also pay attention to the information stated overleaf.

Visit our database to verify the validity of this certificate.

TÜV ®

TÜVNORD

Annex

to certificate registration no. 44 799 26 406749 - 068

Description of product(s):

Module types:	**BIPV Double Glass PV Modules with TOPCon Mono-crystalline Silicon Solar Cells:** ZEB-TP-XX-YYY-ZZZ XX stands for the thickness of the glass (XX = 2, 3, 4, 5, 6, 8, 10, 12 or 15) YYY stands for the number of the cells (YYY = 008 - 144) ZZZ stands for the power (ZZZ = 35 - 685, in steps of 5) Remark: ZZZ indicates rated output power generated from front side under STC
Maximum system voltage:	1500V
Maximum overcurrent protection rating:	30A
Electrical protection class:	Class II
98th percentile module operating temperature (T_{98}):	70°C

Module types:	**BIPV Double Glass PV Modules with BC Mono-crystalline Silicon Solar Cells:** ZEB-BC-XX-YYY-ZZZ XX stands for the thickness of the glass (XX = 2, 3, 4, 5, 6, 8, 10, 12 or 15) YYY stands for the number of the cells (YYY = 008 - 132) ZZZ stands for the power (ZZZ = 40 - 665, in steps of 5) Remark: ZZZ indicates rated output power generated from front side under STC
Maximum system voltage:	1500V
Maximum overcurrent protection rating:	30A
Electrical protection class:	Class II
98th percentile module operating temperature (T_{98}):	70°C

Remark:
For detailed product information, please refer to CDF (Constructional Data Form) with the same file no.

Essen, 2026-02-12

Certification Body - Consumer Products

TÜV NORD CERT GmbH
Am TÜV 1, 45307 Essen, Germany
tuev-nord-cert.de | prodcert@tuev-nord.de

TÜV ®